



UQGS.S24336 Heat-automatic Fire Detectors

Page Bottom

Heat-automatic Fire Detectors

See General Information for Heat-automatic Fire Detectors

NINGBO SENTEK ELECTRONICS CO LTD

S24336

#448 YINCHUN RD

WANGCHUN INDUSTRIAL ZONE

NINGBO, ZHEJIANG 315175 CHINA

Type	Temp Rating F	Smooth Ceiling Spacings		Contact Arrangement	Model No.
		Between Detector	to Wall or Partition		
ROR-FT	135	40	20	NO	HD912-4 (12V)
ROR-FT	135	40	20	NO	HD912-4 (24V)

Compatible Base	Detector Model
P/N854001	HD912-4 (12V), HD912-4 (24)

ROR-FT: Combination rate of rise and fixed temperatures. NO - Normally Open

Last Updated on 2008-08-12

[Questions?](#)

[Notice of Disclaimer](#)

[Page Top](#)

Copyright © 2008 Underwriters Laboratories Inc.®

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Listed and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from Underwriters Laboratories Inc." must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "Copyright © 2008 Underwriters Laboratories Inc.®"

An independent organization working for a safer world with integrity, precision and knowledge.

